

RENO EVENING GAZETTE PROOF OF PUBLICATION

STATE OF NEVADA }
COUNTY OF WASHOE }

LOROTHY YOCOM

being first duly sworn, deposes and says:

That he is the PRINCIPAL CLERK of
THE RENO EVENING GAZETTE, a daily news-
paper published at Reno, in Washoe County, in the
State of Nevada.

That the notice BILL NO: 114

of which a copy is hereto attached, was first published in
said newspaper in its issue dated the 6th day of

March, 1965, and was published in

each issue of said newspaper thereafter for

March 6 only

the full period of 1 days, the last publication

thereof being in the issue dated the 6th day of

March, 1965

Signed Lorothy Yocom

Subscribed and sworn to before me this

6th day of March, 1965

Richard J. Taylor
Notary Public.

NOTICE
NOTICE IS HEREBY GIVEN that Bill No. 114 was introduced before the County Commissioners of Washoe County at a meeting held on the 25th day of February, 1965 and by the said Bill No. 114 it is proposed an ordinance be enacted to amend County Ordinance 86 entitled: "AN ORDINANCE OF THE COUNTY OF WASHOE REGULATING THE INSTALLATION, ALTERATION AND MAINTENANCE OF WARM AIR HEATING SYSTEMS, PROVIDING FOR THE ISSUANCE OF PERMITS FOR WARM AIR HEATING INSTALLATION AND THE INSPECTION THEREOF PROVIDING PENALTIES FOR THE VIOLATION THEREOF, REPEALING ALL ORDINANCES AND PARTS OF ORDINANCES IN CONFLICT THEREWITH."
NOTICE IS HEREBY GIVEN that typewritten copies of the said proposed ordinance have been filed with the County Clerk of the County of Washoe, State of Nevada, for public inspection.
NOTICE IS HEREBY GIVEN that copies of "The National Warm Air Heating and Air Conditioning Code, 1961 Edition, Sixth Edition, 1961" and appendices and amendments, changes and additions thereto, designated as exhibit "A", have been filed with the County Clerk of Washoe County.
NOTICE IS HEREBY FURTHER GIVEN that Bill No. 114 will be read for the last and final time at the regular meeting of the Washoe County Commissioners, Washoe County Courthouse on the 15th day of March, 1965 at 11:30 a.m.
H. K. BROWN,
County Clerk and Clerk of the Board of County Commissioners,
Washoe County, Nevada
March 6, 1965

SUMMARY: An Ordinance amending Ordinance 86 to adopt the National Warm Air Heating and Air Conditioning Code, 1961 Edition.

BILL NO. 114

ORDINANCE NO. 86

AN ORDINANCE TO AMEND COUNTY ORDINANCE 86 ENTITLED: "AN ORDINANCE OF THE COUNTY OF WASHOE REGULATING THE INSTALLATION, ALTERATION AND MAINTENANCE OF WARM AIR HEATING SYSTEMS, PROVIDING FOR THE ISSUANCE OF PERMITS FOR WARM AIR HEATING INSTALLATION AND THE INSPECTION THEREOF, PROVIDING PENALTIES FOR THE VIOLATION THEREOF, REPEALING ALL ORDINANCES AND PARTS OF ORDINANCES IN CONFLICT THEREWITH."

THE BOARD OF COUNTY COMMISSIONERS OF WASHOE COUNTY DO ORDAIN:

Section 1. County Ordinance 86, Section 1 is hereby amended to read as follows:

"Section 1. The National Warm Air Heating and Air Conditioning Code, 1961 Edition and Appendices approved and prepared by the Sheet Metal and Air Conditioning Contractors National Association, Inc., Sixth Edition, 1961, together with such changes as are necessary to make the same applicable to conditions in the County of Washoe and with such other changes as are desirable, all of which changes are marked "Exhibit A" and placed on file in the office of the County Clerk of Washoe County, Nevada, shall be and hereby is adopted by reference, incorporated herein and made a part hereof as if set forth in full."

Section 2. This Ordinance shall be in full force and effect from and after its passage and approval as prescribed by NRS §244.105.

Proposed on the 25th day of February, 1965.
Proposed by Commissioner Sauer
Passed on the 15th day of March, 1965.

Vote:

Ayes: Commissioners: Streeter, Sauer, McKissick and McKenzie

Nays: Commissioners: None
Absent: Commissioners: Cunningham

ATTEST: [Signature]
County Clerk

[Signature]
Chairman of the Board

This Ordinance shall be in force and effect from and after the 15th day of March, 1965.

"EXHIBIT A"

NATIONAL WARM AIR HEATING AND AIR CONDITIONING CODE, 1961 EDITION AND APPENDICES APPROVED AND PREPARED BY THE SHEET METAL AND AIR CONDITIONING CONTRACTORS NATIONAL ASSOCIATION, INC., SIXTH EDITION, 1961, TOGETHER WITH SUCH CHANGES AS ARE NECESSARY TO MAKE THE SAME APPLICABLE TO CONDITIONS IN THE COUNTY OF WASHOE.

Revisions and additions as per County Ordinance No. 86 Passed and adopted March 15, 1965

ARTICLE I

100 - AUTHORITY

Delete first and second paragraphs.

Add: Any reference in this code to numbered manuals shall refer to manuals listed on pages 1 and 2.

Amend 14th paragraph to read: "National Fire Codes" - Volumes 1 through 10, Current Edition of the National Fire Protection Association.

ADD:

100.1 Enforcement will be the Washoe County Building Department.

100.2 Chapter 51 of the Uniform Building Code appendix.

100.3 SCHEDULE OF FEES

Permit Fees: The following table of fees shall apply for heating permits -

For issuing each permit.....	\$1.00
For each air register.....	1.00
For each hot water or steam radiator or convactor or baseboard unit.....	1.00
Where radiant floors or radiant panels are used, it will be assumed as two (2) units per room.	
For each space heater.....	1.00
For each unit heater, high & low static heater.....	1.00
For each circulating type heater, wall panel heaters or safety vent heaters, five (5) or less, each.....	5.00
For each circulating type heater, wall panel heaters or safety vent heaters after the first five (5), each thereafter.....	2.50
For each reinspection - \$1.00 plus 10¢ per mile.	
Any heating investigation for certificate of occupancy, etc., requiring inspection, each inspection - \$1.00 plus 10¢ per mile.	

- 100.4 A heating permit as required by this code may be issued to any person who shall comply with the provisions of the act and the rules and regulations promulgated thereunder of the State of Nevada compiled statutes in reference to the State Contractors Law.
- 100.5 Any person who shall commence any heating work for which a permit is required by this ordinance without first having obtained a permit therefor, shall, if subsequently permitted to obtain a permit, pay double the permit fee fixed by Permit Fee Schedule for such work.
- 100.6 It shall be unlawful and a violation of this ordinance for any person, persons, company or corporation to distribute or service any fuel tank or tanks servicing equipment without first said tanks having metal inspection tags attached thereto issued by the Washoe County Building Department. Said tags giving the number of pieces of equipment being served.
- 100.7 Glass fiber insulation used as lining for air ducts shall present to the air stream a surface especially prepared to resist erosion, and be of not less than one and one-half (1½) pound per cubic foot in weight. Installations shall be cemented in place and secured with welded metal pins and clips spaced at least one (1) for each two (2) square foot of installation. Material facing opposite the direction of air flow shall be securely cemented and coated with adhesive or shall be protected with metal stripping.

ARTICLE IV

400 - FURNACE LOCATION AND MOUNTING

400.1 ACCESSIBILITY:

Change "should" to "shall".

400.2.7 EXCEPTION:

The size of combustion air openings, as specified in National Warm Air Heating and Air Conditioning Code, may be deviated from when opening sizes are designed by a Registered Professional Mechanical Engineer to assure an adequate supply of air for combustion and ventilation.

The Washoe County Building Department may require calculations to be submitted for approval showing the requirements of the system and design criteria.

400.6.6 Access:

Delete "or through a trap door of at least 18 x 24 inches located at some convenient point in the house"; also change "24 inches" to read "30 inches".

3-31-65

(2)

ARTICLE VII

700 - INSTALLATION OF GAS-FIRED, WARM AIR SYSTEMS

700.7.1 Connection Non-Portable Appliances:

Add at end of paragraph: "and shut off valve ahead of tubing."

700.19.1 Material:

Add at end of paragraph: "and be approved."

ARTICLE VIII

800 - INSTALLATION OF OIL-FIRED WARM AIR SYSTEMS

800.4 GRAVITY FEED:

Add at end of paragraph: "and be from tanks with a maximum capacity of 25 gallons."

800.18 OIL FLOW:

Amend paragraphs one and two by changing "275 gallons" to "25 gallons" and changing "550 gallons" to "25 gallons".

ARTICLE X

1000 - WARM AIR SUPPLY DUCT CONSTRUCTION

1000.4 DUCT LININGS:

Add at end of sentence: "and comply with the Washoe County Building Code."